

## CERTIFICATE OF TYPE TESTING IN ACCORDANCE WITH ASHRAE 110 & SEFA 1

CERTIFICATE & REPORT NO: INV/ASHRAE110/1017

DATE: 12th June 2023

**Fume Hood Manufacturer:**  
**Topair Systems INC**  
**300 First Avenue, Suite 102**  
**Needham**  
**MA 02494**  
**USA**



**Fume Hood Model-Type:**  
**FH-120-PP**  
**120cm wide bench-type**

**External Dimensions:**

Width = 1200mm

Height = 2310mm

Depth = 835mm

**Internal Dimensions:**

Width = 1000mm

Height = 1170mm (max)

Depth = 585mm (baffle-sash)

640mm (wall-sash)

**Test Opening:**

**Width: 1000mm**

**Height: 500mm**

**Fume Hood Flow:**

**Face velocity: 99fpm (0.50m/s)**

**Flow rate: 570cfm (970m<sup>3</sup>/hr)**

**Fume Hood Containment:**

**At all test positions: <0.010ppm**

**Test opening scans: <0.050ppm**

**Sash movement effect: <0.010ppm**

This is to certify that the fume hood described above has been type tested in accordance with ASHRAE 110-2016, as required by SEFA 1-2010, and resulted in performance characteristics given in test report INV/ASHRAE110/1012.

**Tested and Certified by: Dr A F Bicen**

A handwritten signature in blue ink that reads 'A.F. Bicen'.



**Invent UK Ltd, 85 Southdown Road, Harpenden, Herts AL5 1PR**  
T: +44 (0) 1582 461666 F: +44 (0) 1582 460077 E: info@invent-uk.com